






Parts List																
ITEM	QTY	SIZE	RATING	TYPE	MATERIAL	PROJ. OUT	FUNCTION	ITEM	QTY	SIZE	RATING	TYPE	MATERIAL	PROJ. OUT	FUNCTION	
A	1	2"	FNPT	COUPLING W/ PIPE AND ELBOW	C.S.	2 1/8"	INTERSTITIAL MONITOR	F	1	-	-	-	C.S.	-	LIFTING LUG	
								G	1	4"	FNPT	COUPLING	C.S.	3"	EMERGENCY VENT PRIMARY	
B	1	4"	FNPT	COUPLING	C.S.	3"	SUPPLY	H	1	4"	FNPT	CPL	C.S.	3"	GAUGE	
C	1	4"	FNPT	COUPLING	C.S.	3"	RETURN	I	1	4"	MNPT	NIPPLE	C.S.	6"	FILL	
D	1	2"	FNPT	COUPLING	C.S.	1 5/8"	NORMAL VENT	J	1	2"	FNPT	COUPLING	C.S.	6"	GAUGE STICK	
E	1	4"	FNPT	COUPLING	C.S.	3 1/4"	EMERGENCY VENT SECONDARY									



Underwriters
Laboratories Inc.
LISTED ®



ALL PROJECTION OUT
DIMENSIONS ARE FROM
THE PRIMARY TANK
W/ EXCEPTION OF
SECONDARY E-VENT &
INTERSTITIAL MONITOR



BASE PLATE ANCHOR HOLE DETAIL

CUSTOMER APPROVAL SIGNATURE/DATE:

500 GALLON HORIZONTAL D/W ABOVE GROUND TANK

DESIGN DATA

OPERATING PRESSURE -ATMOSPHERIC	JOINT DESIGN - PRI./SEC. LAP WELD
SPECIFIC OF GRAVITY - 1.0	ALL LINEAR DIMENSIONS SHALL BE ±¼" AND ANGULAR DIMENSIONS WITHIN ±1°
TANK MATERIAL - ASTM A 36 CARBON STEEL	INTERIOR SURFACES: SSPC-SP-3 POWER TOOL CLEAN WELDS ONLY REMOVE ALL LOOSE DEBRIS
PRIMARY SHELL: 10 GA PRIMARY HEADS: 10 GA	EXTERIOR SURFACES: SSPC-SP-6 COMMERCIAL BLAST TBD
SECONDARY SHELL: 10 GA SECONDARY HEADS: 10 GA	LABEL/MARKING: UNDERWRITERS LABORATORIES UL-142

CUSTOMER:
PROJECT:
AGENT:

GENERAL INDUSTRIES

P.O. BOX 1279 GOLDSBORO, NC 27533
PHONE: (919)751-1791 FAX: (919)751-8186
DRAWING NUMBER: 501200

QUANTITY: ONE (1) REQUIRED
WEIGHT: 2,250 ± 10%