






| Parts List |     |      |        |                            |          |           |                          |      |     |      |        |          |          |           |                        |  |
|------------|-----|------|--------|----------------------------|----------|-----------|--------------------------|------|-----|------|--------|----------|----------|-----------|------------------------|--|
| ITEM       | QTY | SIZE | RATING | TYPE                       | MATERIAL | PROJ. OUT | FUNCTION                 | ITEM | QTY | SIZE | RATING | TYPE     | MATERIAL | PROJ. OUT | FUNCTION               |  |
| A          | 1   | 2"   | FNPT   | COUPLING W/ PIPE AND ELBOW | C.S.     | 2 1/8"    | INTERSTITIAL MONITOR     | F    | 1   | -    | -      | -        | C.S.     | -         | LIFTING LUG            |  |
|            |     |      |        |                            |          |           |                          | G    | 1   | 4"   | FNPT   | COUPLING | C.S.     | 3"        | EMERGENCY VENT PRIMARY |  |
| B          | 1   | 4"   | FNPT   | COUPLING                   | C.S.     | 3"        | SUPPLY                   | H    | 1   | 4"   | FNPT   | CPL      | C.S.     | 3"        | GAUGE                  |  |
| C          | 1   | 4"   | FNPT   | COUPLING                   | C.S.     | 3"        | RETURN                   | I    | 1   | 4"   | MNPT   | NIPPLE   | C.S.     | 6"        | FILL                   |  |
| D          | 1   | 2"   | FNPT   | COUPLING                   | C.S.     | 1 5/8"    | NORMAL VENT              | J    | 1   | 2"   | FNPT   | COUPLING | C.S.     | 6"        | GAUGE STICK            |  |
| E          | 1   | 4"   | FNPT   | COUPLING                   | C.S.     | 3 1/4"    | EMERGENCY VENT SECONDARY |      |     |      |        |          |          |           |                        |  |



Underwriters  
Laboratories Inc.  
LISTED ®



ALL PROJECTION OUT  
DIMENSIONS ARE FROM  
THE PRIMARY TANK  
W/ EXCEPTION OF  
SECONDARY E-VENT &  
INTERSTITIAL MONITOR



BASE PLATE ANCHOR HOLE DETAIL

CUSTOMER APPROVAL SIGNATURE/DATE:

500 GALLON HORIZONTAL D/W ABOVE GROUND TANK

DESIGN DATA

|                                               |                                                                                  |
|-----------------------------------------------|----------------------------------------------------------------------------------|
| OPERATING PRESSURE -ATMOSPHERIC               | JOINT DESIGN - PRI./SEC. LAP WELD                                                |
| SPECIFIC OF GRAVITY - 1.0                     | ALL LINEAR DIMENSIONS SHALL BE ±1/4" AND ANGULAR DIMENSIONS WITHIN ±1°           |
| TANK MATERIAL - ASTM A 36 CARBON STEEL        | INTERIOR SURFACES: SSPC-SP-3 POWER TOOL CLEAN WELDS ONLY REMOVE ALL LOOSE DEBRIS |
| PRIMARY SHELL: 10 GA PRIMARY HEADS: 10 GA     | EXTERIOR SURFACES: SSPC-SP-6 COMMERCIAL BLAST TBD                                |
| SECONDARY SHELL: 10 GA SECONDARY HEADS: 10 GA | LABEL/MARKING: UNDERWRITERS LABORATORIES UL-142                                  |

CUSTOMER:  
PROJECT:  
AGENT:

**GENERAL INDUSTRIES**

P.O. BOX 1279 GOLDSBORO, NC 27533  
PHONE: (919)751-1791 FAX: (919)751-8186  
DRAWING NUMBER: 501201

QUANTITY: ONE (1) REQUIRED  
WEIGHT: 2,250 ± 10%