

PERMATANK® double-wall jacketed underground storage tank features an inner steel tank coupled with an exterior corrosion-resistant fiberglass tank. A unique standoff material separating the inner and outer tanks creates a uniform interstitial space ensuring rapid and accurate leak detection.

Meets EPA Leak Detection Requirements for Underground Storage Tanks

PERMATANK® features:

- Meets UL 58, UL 1746 and ULC-S603.1
- All tanks proven tight throughout installation, via third party certification, by interstitial vacuum test -13 inches Hg minimum
- Provides many options to meet EPA leak detection requirements for interstitial monitoring, including the Permatank Precision Vacuum Monitor
- Steel provides complete compatibility with all blends of ethanol and biodiesel fuels
- Impermeable to all petroleum products and vapors

Additional features:

- Steel inner tank provides structural strength, while its exterior wall of fiberglass reinforced plastic prevents corrosion
- Designed shorter than an all-FRP tank of the same capacity, reducing the cost of installation and increasing site layout flexibility
- Capacities range up to 60,000 gallons

PERMATANK[®] Benefits:

- · Steel construction allows for recycling
- Various backfill options allow for money-saving installation
- Low cost compartments and customization
- Built to nationally-recognized STI standards with strict third-party quality control inspection program



Compatible With a Wide Range of Fuels and Chemicals, Including Biodiesel and Ethanol

PROTECT THE ENVIRONMENT.

BUY RECYCLABLE STEEL TANKS.



Permatank® Double-Wall Jacketed Underground Steel Storage Tanks Optional Manway Monitor Pipe End View Louter Tank Separator Material Separator Material Separator Material Separator Material Flat ends reduce installation costs Provides safe and effective secondary containment Capacities range up to 60,000 gallons

Permatank[®] Guideline Specification

A) General

1. Provide Permatank* double-wall jacketed steel-fiberglass underground storage tanks.

B) Labeling

- 1. Tanks shall bear the Steel Tank Institute Permatank® label.
- 2. Underground tanks shall bear the appropriate Listing label.

C) Product Description

- 1. Tanks shall be manufactured in accordance with Steel Tank Institute Specification for Permatank*.
- Tanks shall be manufactured and listed in accordance with Underwriters Laboratories UL 58, Steel
 Underground Storage Tanks for Flammable and Combustible Liquids and UL 1746, External Corrosion
 Protection Systems for Steel Underground Storage Tanks or ULC-S603.1, Standard for Corrosion Protection
 for Steel Underground Tanks for Flammable and Combustible Liquids.
- 3. All tanks shall provide testable secondary containment and access for interstitial leak detection monitoring.

D) Manufacturer

1. Manufacturer shall be a licensed member company of the Steel Tank Institute and subject to Steel Tank Institute's Quality Assurance program.



